



CITY OF MORRO BAY  
**WATER RECLAMATION FACILITY PROJECT**

***REQUEST FOR PROPOSAL – DESIGN BUILD SERVICES FOR  
WATER RECLAMATION FACILITY (WRF) ONSITE IMPROVEMENTS***

***ADDENDUM NO. 3***


March 29, 2018

Proposers are hereby informed the Request for Proposals issued January 24, 2018 by the City of Morro Bay (City) for the above project has been amended by the following information. A signed copy of this sheet acknowledging the receipt of this addendum shall be included with Proposals.

1. **Schedule:** Revise the last day for formal questions to April 6, 2018.
2. **Attachment A Performance Criteria Report (PCR), Part 1.3 Design-Build Entity & City Responsibilities**, page 1-8: The division of responsibility for “Design, fit-out & permitting of laboratory” shall be DB: Lead, City: Support.
3. **PCR. Part 1.6 Effluent Quality Requirements:** Replace the last paragraph of the section with the following:

The permit for the WRF will include recycled water requirements. The minimum requirements are as defined by CCR Title 22, Division 4, Chapter 3 Water Recycling Criteria, as applicable for Indirect Potable Reuse: Groundwater Replenishment – Subsurface Application (injection wells). DB shall be responsible for providing a WRF that meets the requirements for IPR using injection wells, assuming a 2-month subsurface response time. The WRF product water shall be non-corrosive and have a minimum Langelier Saturation Index of 0.

4. **PCR, Part 2.9 Reverse Osmosis**, design criteria table, RO System Ancillary Equipment – for Optional 3<sup>rd</sup> stage, Item 2: RO High Pressure Pump: Revise criteria to: Horizontal multistage centrifugal or vertical turbine pump.



---

Rob Livick, PE, Public Works Director/City Engineer

---

29 March 2018

Date

---

Acknowledgement of Addendum No. 3

---

Date